



Karnataka Fire & Emergency Services
Office of the District Fire Officer
 Bagaluru Cross Fire Station,
 Kempegowda International Airport Road, Bengaluru-64.



No.04/DFO/BCFS/2025

Dated: 19-02-2025

To,

The Authorized Signatory,
 M/s. MAHESH MEMORIAL
 KENDRIYA VIDYASHALA,
 #33, Doddabommasandra,
 Vidyaranyapura Post,
 Bengaluru-560097.

Sir,

Sub: Issue of "Fire Compliance Certificate" with respect to fire prevention, fire fighting and evacuation measures required at M/s. MAHESH MEMORIAL KENDRIYA VIDYASHALA, Situated at #33, Doddabommasandra, Vidyaranyapura Post, Bengaluru-560097.

Ref: 1) No: 04/ DFO/BCFS/2025 Dated: 20-01-2025.
 2) Your request letter Dated:17-02-2025.
 3) No: 03/ FSO/BCFS/2025 Dated: 18-02-2025.

<<◇>>

With reference to the subject cited (1) above, a conditional fire safety recommendation was issued for M/s. MAHESH MEMORIAL KENDRIYA VIDYASHALA, Situated at #33, Doddabommasandra, Vidyaranyapura Post, Bengaluru-560097. with a condition to fulfil all the recommendation stipulated in Fire safety Recommendation and Compliance the same within 03 months.

With reference cited (2) above, the management of M/s. MAHESH MEMORIAL KENDRIYA VIDYASHALA, had requested for issue of Fire Compliance Certificate from our department. This School Comprising Ground Floor & 02 Upper Floors Only Situated at #33, Doddabommasandra,




Vidyaranyapura Post, Bengaluru-560097. With reference cited (3) above, the building was inspected by Fire Station Officer, Bagaluru Cross Fire Station on 17-02-2025 and Submitted the report & Recommended to Issue the Compliance Certificate.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "Fire compliance Certificate" to M/s. **MAHESH MEMORIAL KENDRIYA VIDYASHALA**, Situated at #33, Doddabommasandra, Vidyaranyapura Post, Bengaluru-560097. Subject to proper maintenance of fire fighting systems in good working condition, providing of one standby generator and to impart training for 40% of employees/staff in basic fire fighting at R.A Mundkur Fire & Emergency Services Academy, Bangalore within 90 days from the date of issue of this report.

"This Clearance report is valid up to 19-01-2026 and is renewable without fail"

Yours faithfully


DISTRICT FIRE OFFICER
Karnataka State Fire & Emergency Services
19/02/25
Bagaluru Cross Fire Station
Bengaluru - 560064